



OPERATING PERMIT APPLICATION

Appendix A

Hazardous Materials Storage

Department of Community & Economic Development

City of Arlington • 18204 59th Ave NE • Arlington, WA 98223 • Phone (360) 403-3551

- An Operating Permit is required when a hazardous material listed in any of the categories in tables 5003.1.1 (1), 5003.1.1 (2), 5003.1.1 (3), or 5003.1.1 (4) of the *Fire Code* is manufactured, stored, or handled; and the quantity of such hazardous material exceeds the quantity listed in the applicable table.
 - This includes any building that is, whole or in part, a “Group H” occupancy; is a pre-existing and non-conforming hazardous occupancy; or has outdoor use of, manufactures, and/or stores materials that exceed the tables for physical and/or health hazard.
- An Operating Permit will not be issued until an inspection has been performed and establishes, to the satisfaction of the Fire Marshal, that the requirements of the *Fire Code* are satisfied; including provisions and requirements regarding manufacture, use, and storage, listed in Chapter 50 of the *Fire Code*.
 - A previous fire safety inspection will not wave this requirement.
- Tests necessary to verify compliance with the *Fire Code* must be performed by the applicant, and the reports of such tests must be provided to the Fire Marshal. These tests and reports vary from product to product; however, they must include the following requirements:
 - Verification of inspection of the fire protection systems
 - Verification of inspection of storage cylinders, tanks, or containers
 - Presentation of Material Safety Data Sheets (MSDS)
 - Verification of compliance with any other applicable State Agency