



**MATERIAL LIST:**

- ① 24"x24"x4" CONCRETE PAD IN UNPAVED AREA
- ② CAST IRON VALVE BOX AND EXTENSION PER STANDARD DETAIL NO. W-190
- ③ 6" GATE VALVE WITH RESILIENT SEAT (MUELLER, M&H OR APPROVED EQUAL)
- ④ MAINLINE SIZE TEE WITH FLANGE
- ⑤ 6" D.I.P.
- ⑥ MEGALUG



APPROVED BY	L. OLIVE
DATE	07/31/2008
REF STAD SPEC	

DEPARTMENT OF PUBLIC WORKS  
**STANDARD DETAILS**

FIRE LINE CONNECTION

STANDARD DETAIL  
NUMBER  
**W-220**