



**NOTES:**

- ① STAINLESS STEEL DOUBLE STRAP SERVICE SADDLE WITH CC THREAD TO BE USED ON ALL MAINS 4" DIAMETER AND LARGER INCLUDING AC MAINS.
- ② CORPORATION STOP, MUELLER OR FORD ONLY, CC x COMPRESSION BALL CORPORATION.
- ③ 1" HDPE CTS SERVICE PIPE (200 PSI RATING). REQUIRES STAINLESS STEEL STIFFENER. #10 TRACER WIRE REQUIRED ON BOTH ENDS.
- ④ 1" COMPRESSION ANGLE METER BALL VALVE X 5/8" METER.
- ⑤ SAMPLING STATION EQUIPMENT TO BE SUPPLIED BY THE DEVELOPER BUT NOT INSTALLED. DELIVER TO CITY OF ARLINGTON UTILITIES DIVISION. THE COMPLETE LIST OF EQUIPMENT COMPONENTS IS AVAILABLE FROM THE CITY OF ARLINGTON UTILITIES DIVISION.
- ⑥ METER BOX SHALL BE MIDSTATES PLASTICS 1324-12 W/READER DI LID.



APPROVED BY	L. OLIVE
DATE	07/31/2008
REF STAD SPEC	

DEPARTMENT OF PUBLIC WORKS  
**STANDARD DETAILS**  
 SAMPLING STATION

STANDARD DETAIL  
 NUMBER  
**W-240**