



NOTES:

1. CARSONITE PLASTIC POST MARKER, BLUE, LABELED "WATER".
2. VALVE MARKER POSTS SHALL BE INSTALLED FOR ALL VALVES LOCATED IN UNPAVED AREAS. VALVE MARKER POSTS SHALL BE SET AS DIRECTED BY THE PUBLIC WORKS INSPECTOR IN A SAFE AND REASONABLY CONSPICUOUS LOCATION.
3. VALVE MARKER POSTS MAY NOT BE REQUIRED FOR AUXILIARY HYDRANT VALVES.



APPROVED BY	L. OLIVE
DATE	07/31/2008
REF STAD SPEC	

DEPARTMENT OF PUBLIC WORKS STANDARD DETAILS
VALVE MARKER POST

STANDARD DETAIL NUMBER W-250
