


NEW DEEP SIDE-SEWER



RETROFIT EXISTING DEEP SIDE-SEWER

NOTES:

1. ANY PLUMBING WITHIN THE BUILDING MUST COMPLY WITH THE CURRENT CITY OF ARLINGTON ADOPTED PLUMBING CODE.
2. THE SIDE-SEWER OUTSIDE THE BUILDING MUST COMPLY WITH THE CITY OF ARLINGTON PUBLIC WORKS CONSTRUCTION STANDARDS.
3. ALL BACKWATER VALVES MUST BE ACCESSIBLE FOR INSPECTION AND MAINTENANCE BY THE OWNER.



APPROVED BY	L. OLIVE
DATE	07/31/2008
REF STAD SPEC	

DEPARTMENT OF PUBLIC WORKS
STANDARD DETAIL

BACK WATER VALVE

STANDARD DETAIL NUMBER

SS-110